ATTESTATION OF CONFORMITY

Issued to:	Dyness Digital Energy Technology Co., LTD. Building 5, 688 Liupu Road, Wuzhong District, Suzhou City, Jiangsu Province, P.R.China
For the product:	Rechargeable Li-ion Battery
Trade name:	DYNESS
Type/Model:	Powerbox G2
Ratings:	Nominal Voltage: 51,2V, rated Energy/Capacity: 10,24kWh/200Ah, Max. Charge/discharge current: 200A
Manufactured by:	DAQIN NEW ENERGY TECH (TAIZHOU) CO., LTD. No.511 West Chenzhuang Road, Sanshui Street, Jiangyan District, 225500 Taizhou City, Jiangsu Province, PEOPLE'S REPUBLIC OF CHINA
Subject:	Complete evaluation of electrical system of the appliances
Requirements:	EN IEC 62040-1:2019

This Attestation is granted on account of an examination by DEKRA, the results of which are laid down in a test file / test report no 6193251,50.

This Attestation implies that the examined types are in accordance with the standards designated under the Low Voltage Directive (LVD) 2014/35/EU.

The examination has been carried out on one single specimen or several specimens of the product, submitted by the manufacturer. The Attestation does not include an assessment of the manufacturer's production. Conformity of this production with the specimen tested by DEKRA is not the responsibility of DEKRA.

This document does not authorize the use of any DEKRA approved mark.

Arnhem, 19 November 2024

Number: 6193251.01AOC

DEKRA Testing and Certification (Shanghai) Ltd.

Kreny Lin

Kreny Lin Certification Manager

© Integral publication of this attestation and adjoining reports is allowed

DEKRA Testing and Certification (Shanghai) Ltd. 5F #250 Jiangchangsan Road Shibei Hi-Tech Park, 200436 Jing'an District, Shanghai, China T +86 21 6056 7666 F +86 21 6056 7555 www.dekra-product-safety.com